

6000PLUS/OPHTCO/TSL - Optical Heat & CO Sensor Plus Talking Sounder & LED Beacon

- Multiple Technology Sensor
- Combined Smoke, Heat and Carbon Monoxide Sensors
- Ideal Multi-Application Sensor
- Integrated Voice Enhanced Sounder
- Integrated High Intensity LED Beacon
- Seven Selectable Voice Messages
- Loop Powered
- Low Current
- Programmable Volume Control
- Integral Short Circuit Isolator
- Protec Algo-Tec™ 6000PLUS Protocol
- Devices Display Address Number
- FAST™ Addressing
- Unprecedented False Alarm Rejection



The Protec Algo-Tec™ 6000PLUS sensor range have been developed to incorporate advanced fire sensing technology, electronic sounders, high intensity LED warning beacons and speech enhanced talking sounder capability, all integrated within the sensor head and powered from the loop.

6000PLUS/OPHTCO/TSL Interactive addressable high performance optical smoke, heat and carbon monoxide multi-sensor.

The ultimate in multi-sensor technology, providing a formidable weapon in the pursuit of reliable fire detection and the avoidance of unwanted or false alarms. The sensor provides total confidence that when initiated, there really is a fire threat.

The sensor incorporates infra-red light scattering for smoke detection, with thermal enhancement of the optical sensitivity, temperature detection equivalent to grade A2, and a third channel incorporating a carbon monoxide (CO) sensing element.

The combination of optical smoke, heat and carbon monoxide gas sensing technology within one fire detector head provides the ideal solution. The sensor can now detect free burning chemical fires, fires producing smoke and low levels of CO and heat, to deep seated smouldering fires, which produce little heat and smoke

but large amounts of CO.


Combining the results from all sensing channels enables rapid fire detection with rejection of false alarms and increased sensor reliability.

Sensor Talking Sounder - For the ultimate method of alerting building occupants of the incidence of an emergency, the Protec Algo-Tec™ 6000PLUS sensor is equipped with an integrated voice enhanced sounder. The talking sounder is capable of delivering synchronised alert and evacuate messages around a building, removing any ambiguity, particularly for anyone unfamiliar with the building alert and evacuation strategy, enabling a more prompt and safe building evacuation.


Sensor Beacon - Compliance with DDA legislation is assisted by the addition of the Protec high intensity LED beacon to warn those with hearing impairments or in noisy environments. The beacon utilises a high intensity LED with lower power consumption and increased reliability when compared to alternative indicators. The beacon is located in the centre of the sensor so can be viewed from all angles. By combining the LED beacon, talking sounder and multi-sensor fire detection technology, we are able to provide the ultimate and most innovative fire detection PLUS alarm system for buildings.

6000PLUS/OPHTCO/TSL Technical Specification

Dimensions (mm)



Typical Wiring using 6000PLUS/BASE



Technical Specification:

Environment	-10°C to +50°C (95% R.H. non condensing)
Ingress Protection	IP41
Weight (excluding base)	105g
Loop Powered	Yes
Loop Standby Load	0.45mA
Loop Alarm Load	13.45mA (15.45mA with Bell Sound)
Loop Voltage	18 - 28V
Isolator	Yes
Sounder Volume	85dB(A) (High), 75dB(A) (Mid), 65dB(A) (Low) <i>(measured at one metre)</i>
Beacon Flash Rate	1Hz
Device Protocol	Algo-Tec™ 6000PLUS
Product Approval	LPCB Certificate No: 201z/04 EC Certificate No: 0832-CPD-1180 Relevant Standard: EN 54-3, 5, 7 & 17, CE Marked

Talking Sounder Message Set

Message Number	Description	Preamble Tone	Duration(s)	Message Text
1	Female evacuation V1	Warble	9.4	Attention please, attention please. Fire has been reported in the building, please leave the building immediately by the nearest exit
2	Female alert	Pulse	7.5	May I have your attention please, an incident has been reported in the building please listen for further instructions
3	Female evacuation V2	Warble	7.5	Attention, attention. This is an emergency. Please leave the building by the nearest available exit
4	Female test	Warble	3.5	This is a test message, no action is required
5	Male evacuation V2	Warble	8	Attention, attention. This is an emergency. Please leave the building by the nearest available exit
6	Male alert	Pulse	8.1	May I have your attention please, an incident has been reported in the building. Please listen for further instructions
7	Male test	Warble	4	This is a test message, no action is required
8	Bell (accessed via msg 14/15)	None	Until Stopped	None
9	No tone or message	None	0	Used by control panel to allow user to 'turn off' sounder part of a talking sounder beacon
10	Bespoke message	W,P or C	max 10 sec	Client defined (must be stated when ordering sounder) additional cost
11	Warble electronic tone	None	Until Stopped	None
12	Pulsed electronic tone	None	Until Stopped	None
13	Continuous electronic tone	None	Until Stopped	None
14	Pulsed bell	None	Until Stopped	None
15	Continuous bell	None	Until Stopped	None

The preamble tone is played for 4 seconds, then a 1 second silence, then the message, then silence until the sequence is re-triggered. This sequence trigger is panel adjustable; preset to 15 seconds.

BASE Options:

6000PLUS/BASE

- Low profile common mounting base

6000PLUS/FFBASE

- Fast fixing semi recessed base

Note - base options above are included in the product approval.



LPCB ref. no. 201z/04



Company Policy is one of continuous improvement, we reserve the right to change specification without prior notice

Protec Fire Detection Plc, Protec House, Churchill Way, Nelson, Lancashire, BB9 6RT

Tel: 01282 717171 Fax: 01282 717273 Web: www.protec.co.uk Email: sales@protec.co.uk

MED1406 Issue 1